



Public Works & Utilities Committee Meeting

Monday, January 10, 2022 at 6:30 pm

CENTRALIA CITY HALL COUNCIL CHAMBERS

114 S. Rollins Street, Centralia, MO 65240

1. CALL TO ORDER

2. ATTENDANCE

Aldermen: Terri Motley, Robert Hudson, David Wilkins, Christina Stevens, Don Rodgers, Landon Magley

3. PLEDGE OF ALLEGIANCE

4. COMMENTS FROM CITIZENS

Public comments may be sent in writing prior to 5:00 p.m. on the meeting date to Mayor Chris Cox at mayor@centraliamo.org or Public Works & Utilities Committee Chairman Robert Hudson at Hudson.r2@gmail.com.

5. WATER AND SEWER DEPARTMENT

- a. Activity Report
- b. Water
- c. Sewer
- d. Other

6. ELECTRIC DEPARTMENT

- a. Activity Report
- b. Generation/Purchase
- c. Distribution
- d. Other

7. PUBLIC WORKS

- a. Activity Report
- b. Streets
- c. Sanitation
- d. Storm Water
- e. Other

8. PUBLIC WORKS & UTILITIES DIRECTOR

- a. Monthly Report

9. AS MAY ARISE

10. ADJOURN

**Activity Report
Water Department
December 2021**

Plant/Distribution Water

- Monthly report
- Monthly work orders
- Monthly locates
- Meeting with Velodyne on slaker issues. Reviewing the process of what the plan is for fitting the slaker to make it run efficiently with our plant.
- Prep all facilities for low temperature season.
- Install new water service for new construction.
- Aaron and Dylan attended water distribution and water treatment class. Took test and are waiting on results for license certifications.
- Met with customer on Bradford St. about water service not buried properly. Notified customer that it needed to be installed properly before weather got cold and caused issues beyond his service.
- Do extensive testing on slaker and taking notes.
- Working on finishing prepping and painting the filter weirs.
- Several discussions on water meter upgrade.
- Checking iron water meters throughout the system.
- Assisted plumbing company that replaced water lines at the Chance Elementary School.
- Checked locations for future new development.
- Work on testing newly added chemical at the water plant to see what we are feeding.

Wastewater Collection System & Lagoons

- Meetings with Fischer Grading out at the City basin location.
- Worked on NW pump house to send water to new basins for testing purposes.
- Checked locations of newly installed gravel and new gates installed.
- Met with B&W and DNR for waste water projection inspection.
- Met with Schmitt irrigation on location and adjustments on WW project.
- Camera sewer on Emerald Dr. to assist plumber, sewer main was clear.
- Check and locate sewer manholes for new & future development.
- Multiple test out at new city basins to determine dirt samples for WW project.
- Coordinate with farmers while moving WW from NW lagoon out to new basins.
- Assist plumber on sewer back up at residential location.
- Check on new construction farmer's basin and progress.

Electric Department Activity December 2021 Report

Locates: 45

Tree Trimming:

- Cut tree down at 402 Kennan-2
- 720 S. Central

Temps and New Services:

- New Service at 909 S. Columbia
- New Service 729 N. Allen

Street Lights:

- Trenched in light at 221 S. Denton
- Boone County bank light
- Replaced D to D at Gas pumps

Underground:

- Located Primary at Columbia/Gano Chance for customer

New Poles and Anchors:

- 1249 E. Hwy 22 new pole-broke from wind storm
- 906 Briarwood

Miscellaneous:

- Osson Cox took end of the year 1st year apprentice final
- Dirt work at Denton/Sunset
- Matt went to MPUA board meeting in Columbia
- Spoke to customer about a service at 107 W. Lakeview
- Tested out new Voltage detector
- Did some situational storm training for wind/ice storm
- Trained on hot sticking from the ground
- Hooked service back up for Railroad crossing
- Trimmed limbs off lines at 420 S. Bradford
- Trimmed limbs off lines at 818 E. Booth
- 803 E. Early- Demo disconnect services
- Fixed Christmas decorations that were bent from wind storm
- Put notices on doors for underground project on Lee/Pratt
- Picked up brush from Brice Giblers property from line clearance
- Spoke to Rick Nelson about old guard office temp power
- Switched over Briarwood from 2 phases to a single-phase line
- Dug Stump out in the shop parking lot

- Completed MIRMA training videos

Outages:

- 421 and 433 Coulter
- 308 S. Bradford-half power
- Between tracks on Jefferson Railroad meter pole broke
- 328 Country Club Dr-pad mount transformer went bad

Matthew Fadler

Electric Department Foreman

310 N. Columbia

City of Centralia, MO

(573)-982-1090

STREET DEPARTMENT

Activity Report for December 2021

- Attended weekly dept head meetings
- Got a load of salt and put into the storage shed
- Dug out and poured concrete to repair street cut on s. Columbia
- Did 48 locates
- Put the snowplows and spreaders on both dump trucks and checked them out and got ready
- Spent several days sweeping streets around town
- Spent several days hauling off brush and leaves at the drop off site out to the old landfill site
- Attended insurance and benefits mtg at city hall on 12/6/2021
- Put up street sign at Walnut and Head that was knocked down
- Replaced the snowplow control cable on dump truck #4
- Finished up some dirt work along block wall by Miles ditch
- Removed old rusted out driveway culvert and set 40ft of 24in metal culvert for the Lutheran Church on Gano-Chance
- Spent a few days patching potholes around town
- Straightened and rewelded hitch on the chipper truck for the Electric dept
- Attended city council meeting on 12/13/2021 (Deme)
- Bladed Rowland, and alley behind pool hall
- Cleaned up around recycling bin a few times
- Pushed brush pit at landfill with the dozer
- Did some ditch cleaning on Pratt, and some on Brick
- Hauled off some tree limbs from high winds
- Hauled off debris pile at the street barn
- Cleaned up concrete form trailer
- Hauled and delivered lots of barricades for the tractor parade
- Decorated the road grader and put it into the tractor parade
- Spent a few days cutting and hauling off brush, cleaning ditch, and lining it with rip-rap and then smoothing and seeding yard on Emerald dr
- Worked on drainage around town

- Watched training videos (Deme, Tyler, Kyle – 3hrs) (Phil – 9hrs)
- Did some sign maintenance
- Winterized the street sweeper
- Spent about 7 days jackhammering, digging, and pouring concrete to repair 6 bad areas on s. Central (148ft x 15ft total road repaired)
- Made sure all equipment was ready to go in cases of snow

From: Mike Forsee, Public Works & Utilities Director

To: Mayor & Board of Aldermen

Date: January 1, 2022

Re: Monthly Report – December 2021



- Met with Heather, Matt Rusch, Martin Construction, and Velodyne (slaker) representatives to discuss options to get the slaker running or not – 3 meetings
- Assisted street crews pour concrete on S. Central at various spots a couple of times
- Contacted Chemco Equipment (previous slaker contractor) to see if still an option if needed
- Met with Fischer Grading on issues at city basins and followed up with Bartlett on solutions and plan of attack
- Teleconference meeting with Bartlett, Benoit, Rhodes and Fischer on barrel testing on new basins
- Attended special meeting with board on meter purchasing with Itron
- Went over wastewater project with DNR during inspection
- Met with Heather on teleconference with Lincoln Brown and Bartlett on storm water funding project
- Met with contractor at Chance Elementary on new water line replacement
- Met with Darren Adams on Furnell Apartments additions
- Met with Blake from Bartlett at Rhodes basin on pump house layout
- Met with Jackie Sue on new house on Southgate
- Gathered prices for equipment and specifications on requested budget items
- Met with Kevin Prenger on possible expansion plans and involvement
- Checked on hydrant replacement on Leabrook and customer tie ins
- Met with Schmitt Irrigation on plans and concerns
- Checked broken pole replacement at Anitoch Baptist Church
- Meeting with Bob Benoit, Schmitt Irrigation, and Matt R. on positioning pivot pad and pipe extension
- Attended benefits luncheon
- Checked road issue at 805 E. Sims
- Met with Andrew Miller on lot on Tidball / Adams for building purposes
- Met with Ginny Zoellers on tractor parade and needs of chamber
- Checked electric concern at 107 W. Lakeview
- Completed MIRMA training for quarter
- Checked setbacks for fences, houses, sheds, and sidewalks